

CITY OF BIRMINGHAM - SUMMARY OF UNPERMITTED DISCHARGES

10/1/17 to 9/30/2018

NOTE: Quantities shown in the column "Est. Volume" are ESTIMATED ONLY. These estimates are the County's best determination of the discharge volume, based upon site-determinable information and accepted estimating methods. However, such estimates are subject to a high number of variables which are completely beyond the County's control and which can have a significant effect upon the calculated amount. Therefore, these estimates are to be used for relative comparison only, not as actual discharge volumes.

Date Reported	Location	Zip	Ultimate Destination	Estimated Volume (gal)	Source	Cause	Weather Conditions	Action Taken
2-Oct-17	3039 Apple Valley Lane	35215	Drainage Ditch/ Feeder to Turkey Creek	15,680	Manhole	Grease/ Roots/ Rags	No Rain	Blockage Removed
2-Oct-17	3039 Apple Valley Lane	35215	Drainage Ditch/ Feeder to Turkey Creek	15,680	Manhole	Grease/ Roots/ Rags	No Rain	Blockage Removed
6-Oct-17	2125 Joyce St	35205	Ground Absorbed	141	Pipe	Service Lined Over	No Rain	Service line was reinstated/ Line Repaired
8-Oct-17	2119 Fulton Ave SW	35211	Storm Drain/ Feeder to Valley Creek	4,160	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
8-Oct-17	530 21st Street SW	35211	Drainage Ditch/ Feeder to Valley Creek	14,283	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
8-Oct-17	530 21st Street SW	35211	Drainage Ditch/ Feeder to Valley Creek	14,283	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
8-Oct-17	530 21st Street SW	35211	Drainage Ditch/ Feeder to Valley Creek	14,283	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
13-Oct-17	6901 Hillcrest Ct	35212	Ground Absorbed	69	Manhole	Grease/ Rags	No Rain	Blockage Removed
13-Oct-17	3301 Laurel Ave SW	35221	Drainage Ditch/ Valley Creek	118	Manhole	Grease/ Debris/ Rags	No Rain	Blockage Removed
18-Oct-17	130 37th Street	35222	Storm Drain	9,154	Manhole	Construction Damage/ Gravity Main Break	No Rain	Line Repaired
28-Oct-17	5700 Oporto Madrid Blvd	35210	Ground Absorbed	45	Cleanout	Grease/ Rags	Moderate Rain	Blockage Removed
1-Nov-17	5721 Monte Sano Road	35228	Ground Absorbed	129	Cleanout	Grease	No Rain	Blockage Removed
19-Nov-17	1131 16th Ave W	35204	Ground Absorbed	44	Cleanout	Grease/ Roots/ Rags	No Rain	Blockage Removed
3-Dec-17	2246 Bessemer Road	35208	Storm Drain	133	Manhole	Grease	No Rain	Blockage Removed
11-Dec-17	1240 Stonehedge Drive	35235	Ground Absorbed		Manhole	Gravity Main Break	No Rain	Line Repaired
18-Dec-17	8312 12th Ave S	35206	Ground Absorbed		Cleanout	Roots	No Rain	Blockage Removed
20-Dec-17	3331 Coalburg Road	35068	Drainage Ditch/ Five Mile Creek	59,250	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
20-Dec-17	2119 Fulton Ave SW	35211	Storm Drain/ Feeder to Valley Creek	13,680	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
20-Dec-17	530 21st Street SW	35211	Drainage Ditch/ Feeder to Valley Creek	62,980	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
20-Dec-17	530 21st Street SW	35211	Drainage Ditch/ Feeder to Valley Creek	62,980	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
27-Dec-17	122 68th Street South	35206	Ground Absorbed		Cleanout	Grease/ Rags	No Rain	Blockage Removed
4-Jan-18	196 Cathy Lane	35215	Storm Drain	198	Manhole	Roots/ Rags	No Rain	Blockage Removed
15-Jan-18	3008 Wilson Road SW	35221	Ground Absorbed	4,350	Manhole	Grease/ Rags	No Rain	Blockage Removed
18-Jan-18	660 Earline Circle	35215	Storm Drain/ Five Mile Creek	783	Manhole	Grease	No Rain	Blockage Removed
21-Jan-18	268 13th Avenue NE	35215	Drainage Ditch	45	Manhole	Grease/ Rags	No Rain	Blockage Removed
22-Jan-18	8236 Rugby Avenue	35206	Storm Drain	7,320	Manhole	Grease/ Debris	No Rain	Blockage Removed
26-Jan-18	404 Old Farm Drive	35215	Ground Absorbed	318	Manhole	Grease/ Rags	No Rain	Blockage Removed
31-Jan-18	605 23rd Lane NW	35215	Ground Absorbed	53	Manhole	Roots	No Rain	Blockage Removed
7-Feb-18	3331 Coalburg Rd	35068	Drainage Ditch/ Five Mile Creek	797	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	3323 & 3401 Ave H & 3322 Ave I	35218	Storm Drain/ Feeder to Village Creek	218,202	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	3323 & 3401 Ave H & 3322 Ave I	35218	Storm Drain/ Feeder to Village Creek	218,202	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	3323 & 3401 Ave H & 3322 Ave I	35218	Storm Drain/ Feeder to Village Creek	218,202	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	530 21st St SW	35211	Storm Drain/ Valley Creek	14,850	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	530 21st St SW	35211	Storm Drain/ Valley Creek	14,850	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	2119 Fulton Ave	35211	Storm Drain/ Valley Creek	26,220	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	1625 Jefferson Avenue	35211	Storm Drain/ Valley Creek	12,618	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	3700 Avenue I	35218	Storm Drain/ Village Creek	60,526	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	13 Avenue W	35214	Ground Absorbed/ Village Creek	4,970	Cleanout	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	3400 32nd Avenue North	35207	Ground Absorbed/ Storm Drain/ Village Creek	1,770	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
7-Feb-18	3008 Wilson Road	35221	Ground Absorbed/ Feeder to Valley Creek	20,496	Manhole	Grease/ Debris	Moderate Rain	Blockage Removed
8-Feb-18	6525 Court K	35228	Drainage Ditch/ Feeder to Valley Creek	3,192	Manhole	Grease/ Rags	Light/Moderate Rain	Blockage Removed
9-Feb-18	3160 30th Court North	35207	Storm Drain	2,560	Manhole	Grease/ Rags	No Rain	Blockage Removed
14-Feb-18	3212 Wenonah Drive SW	35211	Storm Drain	5,400	Manhole	Grease/ Debris/ Rags	No Rain	Blockage Removed
15-Feb-18	1616 Jefferson Avenue SW	35211	Drainage Ditch	9,856	Cleanout	Grease	No Rain	Blockage Removed
16-Feb-18	271 55th Street North	35212	Storm Drain	45	Manhole	Grease/ Rags	No Rain	Blockage Removed
20-Feb-18	310 Summit Blvd	35243	Ground Absorbed	2,488	Cleanout/ Manhole	Grease/ Roots/ Rags	No Rain	Blockage Removed
22-Feb-18	5528 Madison Dr	35228	Ground Absorbed	259	Cleanout	Grease/ Rags	No Rain	Blockage Removed
5-Mar-18	1201 Beacon Parkway E	35209	Ground Absorbed	288	Manhole	Grease/ Roots/ Rags	Weather Conditions	Blockage Removed
5-Mar-18	701 Lower Valley Crest Road	35215	Drainage Ditch/ Tarrant Spring Branch	238	Manhole	Grease/ Debris	No Rain	Blockage Removed
6-Mar-18	530 21st Street SW	35211	Storm Drain/ Valley Creek	81	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
13-Mar-18	7531 65th Courtway S	35212	Ground Absorbed	25	Cleanout	Debris	No Rain	Blockage Removed
16-Mar-18	1524 Five Mile Road	35215	Ground Absorbed		Cleanout	Construction Damage	No Rain	Line Repaired
25-Mar-18	327 Bishop Drive	35215	Ground Absorbed	89	Manhole	Grease/ Rags/ Roots	No Rain	Blockage Removed
26-Mar-18	116 Red Oak Road	35206	Storm Drain/Village Creek		Service Line	Disconnected Service Line	No Rain	Line Repaired
26-Mar-18	3709 3rd Avenue South	35222	Storm Drain	127	Manhole	Grease/ Rags	No Rain	Blockage Removed
27-Mar-18	3439 Colonnade Parkway	35243	Drainage Ditch/Cahaba River	25,665	Manhole	Grease/ Rags/ Debris	No Rain	Blockage Removed
30-Mar-18	3800 Colonnade Parkway	35243	Ground Absorbed/Cahaba River	382	Manhole	Grease/ Rags	No Rain	Blockage Removed
3-Apr-18	1573 Sterilite Drive	35215	Ground Absorbed	1,557	Manhole	Grease/ Rags	No Rain	Blockage Removed
9-Apr-18	4141 Pinson Valley Parkway	35215	Ground Absorbed	8,532	Manhole	Grease/ Rags	No Rain	Blockage Removed
10-Apr-18	6133 Crest Green Road	35212	Ground Absorbed	15	Cleanout	Rags	No Rain	Blockage Removed
12-Apr-18	3212 Wenonah Drive SW	35211	Storm Drain	270	Manhole	Grease	No Rain	Blockage Removed
14-Apr-18	4385 Mountandale Rd	35213	Ground Absorbed/ Shades Creek		Manhole	Surcharge from Rain	Heavy Rain	Not Overflowing Upon Arrival
15-Apr-18	3331 Coalburg Rd	35068	Ground Absorbed/ Five Mile Creek	375,190	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
15-Apr-18	3912 44th Street North	35217	Ground Absorbed/ Village Creek		Cleanout	Surcharge from Rain	Heavy Rain	Line Monitored
17-Apr-18	508 66th Street North	35206	Ground Absorbed/ Storm Drain	228	Manhole	Grease/ Rags	No Rain	Blockage Removed

7-May-18	5339 8th Avenue (Wylam PS)	35224	Ground Absorbed	360	Pump Station	AC Power Failure	No Rain	Power Restored
7-May-18	5824 Court N	35228	Ground Absorbed	4	Cleanout	Bypass Pump	No Rain	Pump Repaired
30-May-18	2119 Fulton Ave SW	35211	Storm Drain/ Valley Creek	155	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
31-May-18	2160 5th Ave N	35203	Storm Drain	4,968	Manhole	Grease	No Rain	Blockage Removed
6-Jun-18	1616 9th Place W & 925 16th Ave W	35204	Ground Absorbed	873	Cleanout/ Manhole	Grease/ Roots	No Rain	Blockage Removed
7-Jun-18	2728 10 Ave S & 2801 University Blvd	35205	Storm Drain/ Valley Creek	1,872	Manhole	Grease/ Roots/ Debris/ Rags	No Rain	Blockage Removed
7-Jun-18	2728 10 Ave S & 2801 University Blvd	35205	Storm Drain/ Valley Creek	1,872	Manhole	Grease/ Roots/ Debris/ Rags	No Rain	Blockage Removed
14-Jun-18	2901 Gallant Place	35215	Storm Drain/ Beaver Creek	2,014	Manhole	Grease	No Rain	Blockage Removed
2-Jul-18	604 Lexington St	35224	Ground Absorbed	12	Cleanout	Connection	No Rain	Reconnected to County Main
1-Aug-18	1930 Warrior Road	35208	Storm Drain/ Valley Creek	90	Manhole	Grease/ Rags	Light Rain	Blockage Removed
6-Aug-18	3709 3rd Avenue South	35222	Storm Drain/ Village Creek	1,170	Manhole	Grease	No Rain	Blockage Removed
10-Aug-18	8912 Valleybrook Road	35206	rainage Ditch/ Village Creek	8,820	Manhole	Grease/ Roots	No Rain	Blockage Removed
11-Aug-18	107 Lakeshore Ridge	35211	Ground Absorbed	855	Manhole	Grease	No Rain	Blockage Removed
28-Aug-18	504 Winterpark Circle	35215	Drainage Ditch/ Tarrant Springs Branch	167	Manhole	Grease/ Roots/ Debris/ Rags	No Rain	Blockage Removed
3-Sep-18	1004 19th Avenue Northwest	35215	Storm Drain/ Barton Branch	2,850	Manhole	Grease/ Rags	No Rain	Blockage Removed
6-Sep-18	1616 Jefferson Avenue	35211	Ground Absorbed	414	Cleanout	Grease/ Rags	No Rain	Blockage Removed
26-Sep-18	2119 & 2126 Fulton Avenue SW	35211	Storm Drain/ Valley Creek	216,164	Manhole	Surcharge from Rain	Light/ Heavy Rain	Line Monitored
26-Sep-18	2119 & 2126 Fulton Avenue SW	35211	Storm Drain/ Valley Creek	216,164	Manhole	Surcharge from Rain	Light/ Heavy Rain	Line Monitored
26-Sep-18	530 21st Street SW	35211	Storm Drain/ Valley Creek	241,200	Manhole	Surcharge from Rain	Light/ Heavy Rain	Line Monitored
26-Sep-18	530 21st Street SW	35211	Storm Drain/ Valley Creek	241,200	Manhole	Surcharge from Rain	Light/ Heavy Rain	Line Monitored
26-Sep-18	2100 Fulton, 2042 Princeton, 201 21st Street	35211	Storm Drain/ Valley Creek	50,230	Manhole	Surcharge from Rain	Light/ Heavy Rain	Line Monitored
26-Sep-18	2100 Fulton, 2042 Princeton, 201 21st Street	35211	Storm Drain/ Valley Creek	50,230	Manhole	Surcharge from Rain	Light/ Heavy Rain	Line Monitored
26-Sep-18	2100 Fulton, 2042 Princeton, 201 21st Street	35211	Storm Drain/ Valley Creek	50,230	Manhole	Surcharge from Rain	Light/ Heavy Rain	Line Monitored
27-Sep-18	2701 23rd Street	35211	Ground Absorbed	1,000	Manhole	Surcharge from Rain	Heavy Rain	Line Monitored
28-Sep-18	2301 Bessemer Road	35208	Storm Drain/ Valley Creek	358	Manhole	Construction Damage/ Gravity Main Break	No Rain	Bypass Pump Setup